



CSIR - NAL Estd. 1959  
ISO 9001: 2008  
CERTIFIED  
ORGANISATION

वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद्  
राष्ट्रीय वांतरिक्ष प्रयोगशालाएं  
**Council of Scientific & Industrial Research  
National Aerospace Laboratories**

पी.वी.सं / PB No. 1779, एचएएल एयरपोर्ट रोड / HAL Airport Road, बेंगलूरु / Bengaluru - 560 017, भारत / INDIA  
फोन / Phone: (का / Off.) : +91-80-2508 6248 / 6247 ; (Res.) : +91-80-4112 7872 ; फैक्स / Fax : +91-80-2521 0113  
<http://www.nal.res.in> ; ई-मेल / E-mail : [harish@nal.res.in](mailto:harish@nal.res.in), [harishbarshilia@yahoo.co.in](mailto:harishbarshilia@yahoo.co.in)

डॉ. हरीश सी.बड़शिलिया  
मुख्य वैज्ञानिक एवं प्रधान  
पृष्ठीय अभियांत्रिकी प्रभाग

**Dr. Harish C. Barshilia**  
Chief Scientist & Head  
Surface Engineering Division

17<sup>th</sup> March 2017

Mr. Ankit  
M/s. Euro Woods (A unit of Straton Group)  
Chennai

Dear Sir,

As per your request dated 14<sup>th</sup> March 2017, we have tested the sample at 5 different places and the average values are given below.

Sample	Reflectance (R)	Emittance (E)	SRI Value
Façade Cladding HPL (Royale Touche – XCL)	0.81	0.83	100

*Sujasf*  
(SRINIVAS-G)

Yours sincerely,

(Harish C Barshilia)  
Head, SED